



**CHECKLIST FOR ANNUAL INSPECTION OF
PLUMBED EMERGENCY SHOWERS**

DATE:

INSPECTOR:

BUILDING:

AREA:

MANUFACTURER:

Please Circle

- | | | | |
|---|----------|----------|------------|
| 1. Is the unit installed in accordance with the manufacturers instructions, including flushing fluid delivery requirements? | Y | N | N/A |
| 2. Is the unit in an accessible location from the potential hazard that requires no more than 10 seconds to reach or approximately 55 feet, same level as the hazard? | Y | N | N/A |
| 3. Is the unit located in an area identified with a highly visible sign positioned so the sign shall be visible in an area served by the emergency shower? | Y | N | N/A |
| 4. Is the area around the emergency shower well-lit? | Y | N | N/A |
| 5. Is the unit positioned so that the shower pattern is dispersed such that the top of the flushing fluid column is at least 208.3cm (82 in.) and not more than 243.8cm (96 in.) from the surface on which the user stands? | Y | N | N/A |
| 6. Is the center of the spray at least 40.6cm (16 in.) from any obstruction? | Y | N | N/A |

- | | | | |
|---|----------|----------|------------|
| 7. Is the unit connected to a supply of flushing fluid per the manufactures installation instructions to produce the required spray pattern for a minimum period of 15 minutes? | Y | N | N/A |
| 8. Are there any leaks in the piping connections? | Y | N | N/A |
| 9. With the valve in the full open position, does valve remain open without requiring further use of the operator's hands? | Y | N | N/A |
| 10. With the valve in the full open position is the diameter of the spray greater than 50.8cm (20 in.) at 152.4cm (60 in.) above the standing surface? | Y | N | N/A |
| 11. Using a flowmeter or other means is the rate of flow at least 75.7 liters per minute (20 gpm)? | Y | N | N/A |
| 12. Using a temperature gauge or other means is the flushing fluid tepid (between 60 and 100 degrees)? | Y | N | N/A |

NOTE: Building Managers shall keep a file of all inspections.