



**CHECKLIST FOR ANNUAL INSPECTION OF
PLUMBED EYEWASH STATIONS**

DATE:

INSPECTOR:

BUILDING:

AREA:

MANUFACTURER:

Please Circle

- | | | | |
|--|----------|----------|------------|
| 1. Is the unit installed in accordance with the manufacturers instructions, including flushing fluid delivery requirements? | Y | N | N/A |
| 2. Is the unit in an accessible location from the potential hazard that requires no more than 10 seconds to reach or approximately 55 feet, same level as the hazard? | Y | N | N/A |
| 3. Is the unit located in an area identified with a highly visible sign positioned so the sign shall be visible in an area served by the emergency eyewash? | Y | N | N/A |
| 4. Is the area around the eyewash station well-lit? | Y | N | N/A |
| 5. Is the unit positioned with the flushing fluid nozzles not less than 83.8cm (33 in.) and no greater than 114.3cm (45 in.) from the surface on which the user stands and 15.3cm (6 in.) minimum from the wall or nearest obstruction | Y | N | N/A |
| 6. Is the unit connected to a supply of flushing fluid per the manufactures installation instructions to produce the required spray pattern for a minimum period of 15 minutes? | Y | N | N/A |
| 7. Are there any leaks in the piping connections? | Y | N | N/A |

- | | | | |
|---|----------|----------|------------|
| 8. With the valve in the full open position, does valve remain open without requiring further use of the operator's hands? | Y | N | N/A |
| 9. With the valve in the full open position will both eyes be washed simultaneously at a velocity low enough to be non-injurious to the user? | Y | N | N/A |
| 10. Using a flowmeter or other means is the rate of flow at least 1.5 liters per minute (0.4 gpm)? | Y | N | N/A |
| 11. Using a temperature gauge or other means is the flushing fluid tepid (between 60 and 100 degrees)? | Y | N | N/A |

NOTE: Building Managers shall keep a file of all inspections.