

Memorandum

May 31, 2012

To: File**From:** Nancy Grossman **Subject: FESHM Chapter 5042 – AC Electrical Power Distribution Safety – For Systems Operating Between 50 and 600 VAC Nominal - has been reviewed and updated by the author.**

The word “approved” has been removed as it related to Nationally Recognized Testing Labs. NRTLs do not approve equipment, they provide a listing for equipment. In addition, the Electrical Hazard Analysis/Work Permit was updated to comply with the 2009 version of NFPA 70E. It did not go out for Lab-wide review, nor does it require Directorate approval.