

**Memorandum**

December 2, 2005


**To:** Gerald Brown  
**From:** William Griffing *WGriff*  
**Subject:** Revised FESHM Chapter 6011 - Periodic Testing of Emergency and Exit Lights

Enclosed you will find revised FESHM Chapter 6011, Periodic Testing of Emergency and Exit Lights. This chapter has been revised to reflect current requirements and operations. It has been reviewed site wide and there were no comments.

After final approval, please return this approval page to Elizabeth May at MS119 for posting on the web.


Encl.

**Recommended for Approval:**

  
\_\_\_\_\_  
Gerald Brown

*12/05/2005*  
\_\_\_\_\_  
Date

**Approved:**

  
\_\_\_\_\_  
Piermaria Oddone

*12/8/05*  
\_\_\_\_\_  
Date

Database login \_\_\_\_\_  
Sent for posting on web \_\_\_\_\_  
Date posted \_\_\_\_\_  
E-mail sent \_\_\_\_\_

## PERIODIC TESTING OF EMERGENCY AND EXIT LIGHTS

### INTRODUCTION

Emergency and exit lights provide illumination for safe exit during power outages. Fermilab has approximately 4000 emergency lights in 330 buildings and enclosures. Fermilab uses a testing program to assure proper light function during emergencies.

### RESPONSIBILITIES

**Divisions/Sections** are responsible for assuring that emergency and exit lights in areas for which they have landlord responsibility are tested periodically according to the procedure outlined below.

Emergency lights are to be tested on a monthly and annual basis as described below. Exit lights are to be tested monthly as described below. Those exit lights powered by an Uninterruptible Power Supply (UPS) are to be tested on an annual basis as well.

### REFERENCE

NFPA 101-7.9, Emergency Lighting National Fire Protection Association 101 Life Safety Code, 2003 ed.

NFPA 101-7.8, 7.10, Exit Lighting Emergency Lighting National Fire Protection Association 101 Life Safety Code, 2003 ed.

### PROCEDURE

1. Tests
  - a. *Monthly Tests.* All emergency/exit lights shall be tested monthly for at least 30 seconds by activation of the test mechanism, unplugging the unit, or activating the local circuit breaker. The light passes the test if it emits a plainly visible light for the duration of the test.

- b. *Annual Tests.* All emergency lights (and appropriate exit lights) shall be tested annually by activation of the test mechanism or unplugging the unit for at least 90 minutes. The light passes the test if it emits a plainly visible light at the end of the test.
- c. *Exception.* Emergency lighting units located in beamlines generally inaccessible to personnel due to beamline operation are exempted from the requirements of 1.a and 1.b above. Units in such areas shall be tested as follows:
  - (i) Operating Periods (Generally inaccessible to personnel) - no testing required.
  - (ii) Shutdown Periods (Generally accessible to qualified personnel), Duration of Less Than 10 Days - no testing required.
  - (iii) Shutdown Periods, Duration of 10 Days to 30 Days - one-30 second test during the shutdown period.
  - (iv) Shutdown Periods, Duration of 30 Days to 1 Year - one 90 minute test during the shutdown period and 30 second tests at 30 day intervals for the duration of the shutdown period.
  - (v) Shutdown Periods, Duration Greater Than 1 Year - follow the requirements of 1.a and 1.b above.

## 2. Documentation

- a. *Inventories.* Each division/section is responsible for keeping a comprehensive inventory of emergency lights in its areas. Light locations will be recorded in a fashion that allows maintenance personnel to quickly locate the lights.
- b. *Monthly Tests.* A record of each test shall be maintained in one of two ways:
  - (i) An *Emergency Light Inspection Record* tag attached to each light and filled in after each test (the inspection tags are available from the ES&H Section), or
  - (ii) A division/section central record showing the date of each test, the tester's initials, and a mark denoting either *pass* or *fail*.

- c. *Annual Tests.* Each annual test shall be documented in the same fashion as the monthly test. Card replacement shall occur at the time of the annual test.
- d. *Archives.* All used emergency light cards or records shall be kept in an auditable fashion by the division/section for a period of three years.

3. Repair

Requests for light repair/alteration/replacement should be placed with Facilities Engineering Services Section through Work Central, x-3434. Lights should be repaired, altered or replaced as follows:

- a. *Test Failure.* If a light fails any test, it should be promptly repaired or replaced as needed.
- b. *Lack of Convenient Means of Testing.* An emergency light lacking both a test button and an external plug/socket combination should be altered or replaced.
- c. *Inconvenient Light Placement.* Emergency lights mounted out of reach should have their testing mechanisms (i.e., test buttons and/or wall sockets) lowered to facilitate testing.