

Memorandum

February 1, 2013


To: Jack W. Anderson
From: Nancy Grossman *NG*
Subject: Revised FESHM Chapter 6020.3 – Storage and Use of Flammable Gases

Changes to this chapter include:

- Modified risk class 0 and risk class 1 requirement to be compatible with FESHM 5031.1 and design practices.
- Applied FESHM format Template.
- Incorporated the Fire Department to the review process.
- Added Engineering Note to definitions.
- Changed Fire Safety Subcommittee to Fire Hazard Subcommittee.
- Replaced PPD Engineering contact information with document links.
- Renamed Table 1 from Figure 1 to match text reference in flow chart.
- Added Requirement 12 in Section 6.1 regarding piping design
- Added Requirement 13 in Section 6.1 regarding PVC vent piping.
- Relocated pipe joints from Section 6.2,3 to 2,f.
- Changed provision for leak testing at 90% to 125% in Section 6.2,4.
- Change chemist to SSO in Section 6.2, 14.

This chapter went out for lab-wide review and all comments were addressed. After Directorate approval, please return this approval page to Jody Federwitz at MS119 for posting on the web.

Encl.

Recommended for Approval:

Jack W. Anderson*Feb. 4, 2013*

Date**Approved:**

Piermaria Oddone*Feb 5/13*

Date