

## FESHM 8081: REFRIGERANT MANAGEMENT

### Revision History

<b>Author</b>	<b>Description of Change</b>	<b>Revision Date</b>
Teri Dykhuis	Clarify that all refrigerants, including the initial charge of equipment, must come from the stockroom.	November 2019
Teri Dykhuis	Added “HFC” to the list of substances within the definition of ‘Certified Technician/Sub-Contractor’	April 2019
Teri Dykhuis	Updated to reflect Fermilab leased spaces.	January 2018
Bridget Iverson	<ul style="list-style-type: none"><li>• Reflecting changes that resulted from the reorganization of the ESH&amp;Q Section.</li><li>• Include recommendations identified during a tripartite assessment of FESHM environmental chapters.</li><li>• Updated to include reorganization of storeroom to stockroom.</li></ul>	February 2016
Rod Walton	Added reference to HFCs as subject to this chapter and federal law.	September 2014
Rod Walton	Added FESHM Chapter formatting and minor wording changes.	September 2013
Rod Walton	Initial release Chapter 8081	December 2008

## TABLE OF CONTENTS

<b>1.0</b>	INTRODUCTION.....	3
<b>2.0</b>	DEFINITIONS .....	3
<b>3.0</b>	RESPONSIBILITIES.....	4
<b>3.1</b>	Divisions/Sections/Projects (D/S/P).....	4
<b>3.2</b>	FESS.....	5
<b>3.3</b>	Logistics Property & Control .....	5
<b>3.4</b>	Refrigerant Manager.....	5
<b>4.0</b>	PROCEDURES.....	5

## 1.0 INTRODUCTION

The purpose of this FESHM chapter is to establish and promulgate the procedures for managing refrigerants at the Fermilab site in Batavia, Illinois. All Fermilab leased spaces shall comply with provisions in §608 of the Clean Air Act, USEPA regulations at 40 CFR 82, SARA and conditions listed in the policies, procedures, and/or programs for that leased space.

Refrigerants can pose environmental hazards if released into the environment because of their potential as greenhouse gases (GHG) and/or stratospheric ozone depleting substances (ODS). The potential hazard of a specific refrigerant as GHG is quantified as its Global Warming Potential (GWP), and likewise, the hazard as an ODS is its ozone depleting potential (ODP). Because of this potential, refrigerants are strictly regulated by provisions in §608 of the Clean Air Act, USEPA regulations at 40 CFR 82 and Illinois regulations at 35 IAC 200 *et seq.* A major part of the regulations requires that refrigerant use by certified technicians must be accurately tracked, and that all refrigerant materials are strictly accounted for and documented by owners of equipment having a charge of 50 pounds or more.

The Superfund Amendments and Re-authorization Act (SARA) requires reports each year to local emergency management agencies and USEPA on the total inventories of refrigerants, and the additional amount of refrigerants in use, or inadvertently released, each year.

The §608 rule requires that a facility like Fermilab have a Refrigerant Manager (RM) to coordinate all activities in which refrigerants are used. This chapter establishes that position within FESS Operations for Fermilab in Batavia, Illinois, and outlines the responsibilities of the RM. It also establishes the procedures whereby all refrigerants (including CFCs, HCFCs, and HFCs) used at Fermilab, regardless of the actual point of use and whether the certified technician is a Laboratory employee or a sub-contractor, shall be managed through the RM.

This chapter does not apply to cryogenic substances, such as helium, neon, hydrogen, argon, nitrogen and oxygen that are not ODS.

## 2.0 DEFINITIONS

Certified Technician/Sub-Contractor – any person who performs maintenance, service, or repair that could reasonably be expected to release class I (CFC), class II (HCFC), or HFC substances from appliances.

CFC – Chlorofluorocarbon – any chemical listed as a Class 1 ODS in Sections 608 and 609 of Clean Air Act

GHG – Greenhouse Gas – a gas in an atmosphere that absorbs and emits radiation within the thermal infrared range. This process is the fundamental cause of the greenhouse effect.

GWP – Global Warming Potential – the ratio of the warming of the atmosphere caused by a GHG to the warming caused by a similar mass of carbon dioxide.

HCFC – Hydrochlorofluorocarbon – any chemical listed as a Class II ODS in Section 608 or 609 of the Clean Air Act.

HFC – Hydrofluorocarbons – HFCs are a class of replacements for CFCs. Because they do not contain chlorine or bromine, they do not deplete the ozone layer. All HFCs have an ozone depletion potential of 0. Some HFCs have high global warming potentials.

LPC – Logistics Property & Control

ODP - Ozone Depleting Potential – the ratio of the impact on ozone of a chemical compared to the impact of a similar mass of CFC-11.

ODS – Ozone Depleting Substances – any of several classes of organic compounds including chlorofluorocarbons (CFCs), hydrochlorofluorocarbons (HCFCs), halons, and related chlorinated compounds that have been designated by EPA as contributing to the destruction of stratospheric ozone.

RM – Refrigerant Manager

USEPA – United States Environmental Protection Agency

## **3.0 RESPONSIBILITIES**

### **3.1 Divisions/Sections/Projects (D/S/P)**

The D/S/Ps shall ensure that:

- All refrigeration equipment for which they are responsible is maintained and serviced in such a way as to prevent and minimize releases of ODS to the environment.
- Equipment is subjected to periodic review to eliminate the use of Class I ODS refrigerants whenever practical.
- Provide the RM with equipment additions including manufacturer, model, serial number, exact location and refrigerant type and quantity.
- The RM is informed in a timely manner as to the types and quantities of specific refrigerants needed for D/S/P operations.
- Refrigerant sub-contractors, who are under contract with Divisions, Sections, or Projects, are aware of this procedure, and that all refrigerants, including initial charge of equipment, must be checked out from the Site 38 Stockroom.
- Technicians, whether Fermilab employees or sub-contractors, have the appropriate USEPA certification level to evacuate and/or charge a system. Documentation shall be provided to the RM prior to work being performed.
- Documentation of refrigerant use and/or release is provided to the Fermilab RM for reporting purposes.
- Leaks exceeding the annual leak rate are repaired within 30 days.
- When leak repairs are made, that the equipment is rechecked and the results are

forwarded to the RM within 30 days.

### 3.2 FESS

FESS shall:

- Provide documentation for annual reporting related to SARA Title II & III to the ES&H Section in a timely manner, so that reports to the appropriate agencies can be prepared and submitted.

### 3.3 Logistics Property & Control

LPC shall:

- Maintain the inventory of all refrigerants at the Site 38 Stockroom.
- Enter purchases and disposals into the data collection software.
- Ensure that only certified technicians are issued refrigerants, and document the certification for all technicians.
- Verify the certification of technicians purchasing refrigerant and/or recovery cylinders.
- Check out and accept returned refrigerant and recovery cylinders to/from certified technicians, either employees of Fermilab or sub-contractors, and verify the use of refrigerant from the containers by weight.

### 3.4 Refrigerant Manager

The RM shall:

- Maintain the database of equipment at the Laboratory that requires refrigerant.
- Maintain the Refrigerant Compliance Management (RCM) database that tracks refrigerant use and releases.
- Provide annual reporting to ES&H.

## 4.0 PROCEDURES

1. Employees or sub-contractors must complete a “Refrigerant Service Order Form” in order to receive refrigerant from the Site 38 Stockroom. All refrigerants, including initial charge of equipment, must come from the stockroom.

**Note:** *Only EPA certified refrigeration technicians are permitted to perform maintenance on a system containing refrigerant that has the potential for losing gas to the atmosphere.*

2. Cylinders will be checked out to properly certified technicians upon a one-time verification of their certification status. Each cylinder is uniquely identified, and each cylinder weight will be recorded when issued and upon return to the Site 38 Stockroom.
3. Equipment information from the Refrigerant Service Order Form will be transcribed by the RM or designee into the database.
4. Unused cylinders must be returned to the Site 38 Stockroom, checked in and

weighed. All information shall be transcribed by the stockroom employees into the RCM database.

5. Sub-contractors must return cylinders each day to be weighed and checked back in to the inventory.